

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for WEIRTON AREA WATER BOARD, WV3300516

Our water system violated drinking water monitoring requirements within the past year. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation.

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we failed to submit the required samples/reports as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do? There is nothing you need to do at this time.

The table below lists the reporting we did not conduct, how when the report should have been submitted.

Required Monitoring	FedRep ID	Required Reporting	Compliance Period
VIOLATION: 52	2018-535781	REQUIRED LEAD AND COPPER SAMPLE RESULTS NOT SUBMITTED	01/01/2018 to 06/30/2018
VIOLATION: 32	2018-535772	FAILURE TO SUBMIT LT2 SAMPLE RESULT	06/01/2017 to 06/30/2017

What happened? What is being done? (Describe corrective action)

Violation 52: During the lead & copper survey, Alt. sample sites are used when customers move or cannot get access to house, These Alt. sites must be preapproved before samples can be gotten. The WAWB submitted samples from our Alt. list of customers not realizing that they were not preapproved. We did get the Alt. sites approved and the test results are valid.

Violation: 32 The LT2 results were sent to the proper office on 9/17/17. It was sent late due to the third-party lab doing the testing, Sending the results to the WAWB late

For more information, please contact Sam Stoneking Jr at 304-740-5020
(Contact Name) (Phone Number)
or 125 E. Belleview Dr., Weirton, WV 262062
(Mailing Address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by **WEIRTON AREA WATER BOARD**

State Water System ID# WV3300516

Date Distributed 10/3/2018